

MINUTES OF THE REGULAR MEETING  
OF THE BOARD OF DIRECTORS OF  
COUNTY SANITATION DISTRICT NO. 18  
HELD AT THE OFFICE OF THE DISTRICT

February 28, 2024  
1:30 o'clock, P.M.

The Board of Directors of County Sanitation District No. 18 of Los Angeles County met in regular session.

There were present: Dan Koops, Director from Bellflower  
Bruce Barrows, Director from Cerritos  
Cory C. Moss, Director from Industry  
Carol Engelhardt, Director from La Habra Heights  
Steve De Ruse, Director from La Mirada  
Rick Ramirez, Alternate Director from Norwalk  
Gustavo Camacho, Alternate Director from Pico Rivera  
Lindsey Horvath, Director from Los Angeles County  
Ali Sajjad Taj, Chairperson, Alternate Director from Artesia

Absent: Mario Trujillo, Director from Downey  
Jay Sarno, Director from Santa Fe Springs  
Joe Vinatieri, Director from Whittier

Also present: Kimberly S. Christensen, Secretary to the Board  
Jessica Lienau, District Counsel

RE: PUBLIC COMMENT The Chairperson announced this was the time for any questions or comments by members of the public. There were no public comments or questions to address the Board on any matters.

RE: DIRECTOR FROM CITY OF LA HABRA HEIGHTS A certificate from the City Manager's Office of the City of La Habra Heights was presented to the Secretary stating that at a meeting of the City Council held December 11, 2023, Ms. Carol Engelhardt was elected Mayor of the City of La Habra Heights, which is the designation of the presiding officer of the governing body of that city and automatically places Ms. Engelhardt on this Board.

Upon motion of Director Moss, duly seconded and unanimously carried, the certificate was accepted and ordered filed.

RE: ALTERNATE DIRECTOR FROM CITY OF LA HABRA HEIGHTS A copy of an action taken by the City Council of the City of La Habra Heights at a meeting held December 11, 2023, was presented to the Secretary stating that Mr. John Pespisa, a member of the City Council of the City of La Habra Heights, was appointed to serve as alternate Director from the city.

Upon motion of Director Moss, duly seconded and unanimously carried, the action was accepted and ordered filed.

RE: ALTERNATE DIRECTOR FROM CITY OF NORWALK A copy of an action taken by the City Council of the City of Norwalk at a meeting held February 6, 2024, was presented to the Secretary stating that Mr. Rick Ramirez, a member of the City Council of the City of Norwalk, was appointed to serve as alternate Director from the city.

Upon motion of Director Moss, duly seconded and unanimously carried, the action was accepted and ordered filed.

RE: DIRECTOR FROM CITY OF SANTA FE SPRINGS A certificate from the Deputy City Clerk of the City of Santa Fe Springs was presented to the Secretary stating that at a meeting of the City Council held January 11, 2024, Mr. Jay Sarno was elected Mayor of the City of Santa Fe Springs, which is the designation of the presiding officer of the governing body of that city and automatically places Mr. Sarno on this Board.

Upon motion of Director Moss, duly seconded and unanimously carried, the certificate was accepted and ordered filed.

RE: ALTERNATE DIRECTOR  
FROM CITY OF SANTA FE SPRINGS

A copy of an action taken by the City Council of the City of Santa Fe Springs at a meeting held January 11, 2024, was presented to the Secretary stating that Mr. William

Rounds, a member of the City Council of the City of Santa Fe Springs, was appointed to serve as alternate Director from the city.

Upon motion of Director Moss, duly seconded and unanimously carried, the action was accepted and ordered filed.

RE: MINUTES

Upon motion of Director Moss, duly seconded and unanimously carried, the minutes of the regular meeting

held January 24, 2024, were approved.

RE: DISTRICT EXPENSES

The following expenses for the month of November 2023, were presented and upon motion of Director Moss, duly

seconded and unanimously carried, were approved:

Local District Expenses:

Operations & Maintenance \$ 3,540

Allocated Expenses:

Joint Outfall 13,798,650

Total Expenses \$13,802,190

RE: ANNUAL COMPREHENSIVE  
FINANCIAL REPORT FOR FISCAL  
YEAR ENDING JUNE 30, 2023  
RECEIVE AND ORDER FILED

The Districts' *Annual Comprehensive Financial Report* (ACFR) for the fiscal year ending June 30, 2023, which includes the annual audit required by state and federal laws, has been previously distributed to the Directors.

This item is consistent with the Districts' Guiding Principles of commitment to fiscal responsibility and prudent financial stewardship; and to protect financial and facility assets through prudent investment and maintenance programs. A recommendation was made to receive and order filed the Districts' ACFR for fiscal year ending June 30, 2023.

The Chief Engineer and General Manager advised that all of the agendas include an item to receive and file the ACFR, which includes the annual audit required by state and federal laws. The ACFR was reviewed by an independent Certified Public Accounting firm and there were no findings of concern. The agency maintained a high credit rating, and the CalPERS pension is funded at 90 percent. The first several pages in the ACFR include a management summary that discusses the Districts' capital projects, goals, an overview of the Districts' wastewater and solid waste operations, and financial position.

Upon motion of Director Moss, duly seconded and unanimously carried, the *Annual Comprehensive Financial Report* for fiscal year ending June 30, 2023, which includes the annual audit required by state and federal laws, and was previously distributed to the Directors, was accepted and ordered filed.

RE: DISTRICTS' OPERATIONS DURING  
RECENT STORMS - DISCUSS

The Chief Engineer and General Manager stated that he is providing a detailed report on the February storms discussed in a recent email that included details of

various Sanitary Sewer Overflows (SSOs) and a press release regarding the cause of the SSOs.

He gave some background on the Districts' sewer system. The Districts operates and owns treatment plants and a large, interconnected sewer system, also known as the Joint Outfall System (JOS). All local sewer lines (city and county) connect to the JOS, as was shown on a map. There were unprecedented storms that occurred in early February 2024. The Districts can tie into Los Angeles County Department of Public Works Rain Gauge Data. The cumulative rainfall from February 1-8, 2024, was shown on a map of the JOS. The foothills in the San Gabriel Valley saw rainfall of over 11 inches.

During two storms that occurred on February 1 and 4-6, staff saw significant increases in flow to treatment plants. The Districts' treatment plants remained online 100 percent, handled record flows, and experienced only minor issues. The treatment plants took all incoming flow from the cities and the County of Los Angeles. All pumping plants were online 100 percent with no pumping limitations. There were no blockages

or structural failures, as had occurred with the spill in Carson in 2021, that caused issues. He stated that the Sanitary Sewer Overflows (SSOs) were caused by stormwater entering the sewer system, not equipment or structural failure.

SSOs occurred in nine locations, as was shown on a map. Most of the overflows were relatively small at 20-60,000 gallons. One SSO located in Rancho Dominguez spilled a total of 8 million gallons, and wastewater ran into the Dominguez Channel, Los Angeles River, and the harbor and ports of Long Beach and Los Angeles.

The storms caused region-wide street flooding, as was shown in photos. There were advisories to the public against driving during street flooding. When street flooding occurs, staff sees a direct impact to sewer flows. He showed a photo of a service worker from the City of Los Angeles relieving a flooded street during this last storm by opening the manhole cover to allow water to drain into the sanitary sewer. While it may have relieved the problem of flooded streets, it only pushes the problem further downstream, and can lead to SSOs. The stormwater inflow impacts on the Rancho Dominguez Sewer, shown on a line graph, revealed a pattern of increased rain levels and concurrent significant increases in sewer flow on February 1 and 4-6. On February 4, the intense rain caused the sewer level to “skyrocket,” which caused pressure to build in the sewer that pushed out water from the manhole and junction structure covers and damaged the surrounding asphalt, as was shown in a photo.

He showed a photo of a typical manhole cover. A manhole cover is designed to provide access to a sewer and can withstand roadway traffic. A manhole has a metal rim and holes to allow for a crowbar to lift the cover. Manholes are not watertight. Ideally, the stormwater and sanitary sewer systems stay separated, as was shown in a photo. Storm drains are located at the edge of the roadway. Some cities install screens to storm drains to filter debris. Sewer manholes are located at the crown or center of the roads. The two systems are completely separate, although there is always incidental water that enters the sewer system. The heavy rainfall and street flooding causes the manholes in many locations to be completely submerged in water, allowing the rainwater to enter the sewer system from the lip or holes of the manhole.

He discussed a bar graph showing the stormwater impacts to peak and average daily flows to JOS treatment plants. In the days preceding the storms of February 1 and February 4-6, the typical peak and average flows were 500 and 380 million gallons per day. However, during the storms, peak and average daily flows to the JOS significantly increased and doubled during the second storm that hit Los Angeles County from February 4-6. When the rainfall subsided then the flows returned to normal.

In response to Director Barakat, City of Bradbury, the Chief Engineer and General Manager advised the Districts’ system was able to take a lot more flow, but SSOs still occurred throughout the system. Once the tunnel is constructed, while it would provide additional capacity for getting treated effluent flow out of the Warren Facility, it would not affect the capacity of getting raw sewage into the Warren Facility.

In response to Director Liu, City of Diamond Bar, the Chief Engineer and General Manager advised that the storm drain system is completely separate and different from the District’s sewer system.

He showed more photos of street flooding and advised of the importance of preventing flooding, by allowing catch basins to flow unimpeded. He further advised of the importance of the corking and sealing manholes to prevent stormwater inflow. It’s a practice that Districts implement in the JOS, and the Districts would offer supplies to the cities and county free of charge for their sanitary sewer systems. He then advised of two different commonly used methods to identifying sources of stormwater inflow to sanitary sewer systems, which included smoke testing and/or dye testing. Smoke testing involves introducing smoke into the sewer system to see where it may daylight out of the system through connections, while dye testing involves the release of an inert/non-reactive dye to the drain to trace whether it is connected to the sewer system. Districts’ staff would be available to support cities and the county in identifying areas of high stormwater inflow for further study. Lastly, he advised that the Districts has sent a letter to City Managers and Public Works Directors regarding action requested to prevent sewer overflows during storms. Hardcopies of the letter were also attached to Directors’ agendas. He summarized the specific actions as follows:

- Prevent - Keep stormwater catch basins cleared to minimize street flooding.
- Train - Train staff (e.g., Public Works, Police, Fire Department) not to remove a sanitary sewer manhole cover to drain a flooded street.
- Prepare - Seal manhole covers that may become submerged. The Districts will provide caulk or silicone and corks free of charge upon request for sealing manhole covers.

- Tell Us - If you are aware of any areas that are subject to flooding during rain events, provide the Districts with the location and approximate boundaries so that staff can determine if there is potential for inflow of storm flows.

He reiterated that staff could provide support to cities and the county for inflow and infiltration studies that involve smoke or dye tests to show illegal connections. These actions are requested to prepare for this wet season and beyond. This letter to the cities and the county is an important resource for management issues. The Districts can assist cities and the county to identify problem areas. He advised that Districts' staff is already working with the City of Long Beach and has a planned meeting with the City of Whittier to address these issues.

In response to Director Finlay, City of Duarte, the Chief Engineer and General Manager advised that the worst flooding was contained in the residential areas. Litter control is a key to avoiding future flooding. Some manholes are for the storm drain system and other utilities. A Sanitation Districts' manhole will contain sewage.

In response to Director Clark, City of Rosemead, the Chief Engineer and General Manager advised that street flooding is accidental. Sometimes there are inappropriate and illegal connections to the system or plumbers inadvertently connect due to the lack of knowledge.

The Chief Engineer and General Manager reminded the Directors that as a result of a third-party audit (following the 2021 Carson spill), the Districts initiated the development of a sewer flow model and monitoring system. He showed a map of the flow meters recently authorized by the Board for a portion of the JOS. While the monitoring system is necessary for the ongoing development of the sewer flow model, it has already paid dividends by identifying stormwater inflow issues in real-time. The Districts will add more meters in the north portion of the system next year to support the expansion of sewer model. In its entirety, the sewer model and monitoring system will allow the Districts to better manage the sewer system during rainy seasons, and it will be a great tool for staff to identify stormwater inflow hotspots and/or provide cities with information on where to focus their efforts to control inflow. He plans to discuss the matter with the Personnel Committee to determine the best way to assist cities and the county to get ahead of this problem.

Director Lustro, City of Pomona, requested a copy of the slide presentation.

Upon motion of Director Moss, duly seconded and unanimously carried, the meeting was adjourned.

ALI SAJJAD TAJ  
Chairperson

ATTEST:

KIMBERLY S. CHRISTENSEN  
Secretary

/ee